EREC Quality Safety & Trust

Erec India Research Laboratory

NABL
Certificate Nos.:
NABL/T-1762

(NABL Accredited/Govt. Approved Laboratory)

ENGINEERING SECTION

Structural Stability Certificate

Ref No: EREC/NDT/BK/2021/012
Date : 06.06.2021

Certified that the RCC School buildings under name and style "St. Mary's Senior Secondary School" Maligaon, Guwahati-781011, Kamrup (M), Assam is duly inspected by us (EREC Team) and carryout the NDT Test for issue the Technical Safety Certificate against Stability of RCC buildings as on date.

*The test data recorded during testing and physical observations are thoroughly analyzed. And after analyzing & scrutinizing the whole data, the average compressive strength of the building is found >30 N/mm^2. Scrutinizing the resultant strength, it can be revealed that the quality of concrete of the building may be considered under the category of ~~Poor~~/~~Normal~~ **/Standard/**~~Excellent.~~ The Building is safe and durable at present condition.*

Verified & Recommended.

06/6/21

Executive Engineer
PWD BLDG. Div.
Chandmari, Guwahati-03

S. Grace Ottalankal
Manager
St. Mary's Sr Sec School
Maligaon, Guwahati-11

Principal
St. Mary's Sr. Sec. School
Maligaon, Guwahati-781011
(Assam)

BEST QUALITY ORIGINAL GENUINE AUTHENTIC

Signature of Lab- In-charge

6/6/2021.

Dr. Mahidhar Pathak
Chartered Engineer
(Regd. No. AM 76811/4)
(CEO cum TM)

EREC INDIA RESEARCH LABORATORY GUWAHATI

Office : EREC Lab, Rupnagar, Guwahati – 781032, Assam.
Phone No. : 90850-66613, 98640-66613, E-mail: mpguw2@rediffmail.com
www.erecindia.com

The Institution of Engineers (India)

AM 76811/4

By virtue of Professional training, experience and Corporate Membership of this Institution

MAHI DHAR PATHAK

is hereby authorised to use the style and title of

Chartered Engineer [India]

Dated this Twentyfirst day of March 1994

Er. M. Pathak
Regd. No. AM-76811/4
Chartered Engineer

EREC INDIA RESEARCH LABORATORY
GUWAHATI

Secretary and Director General